

Analysis Report

Date: 16/01/2023 Date & Time of sample collection: 12/01/2023 AR No: AR /ABL/2073/ 2023 Name: NAVABHARATH CENTRAL SCHOOL Mob: 9947191922 : Client Sample collected by Email: : Client Address: PARAMBILPEEDIKA P.O Sample delivered by : 12/01/2023, 10.00 A M Date & Time of delivery : Lab Analyst Sample received by Source of Sample: OPEN WELL WATER :Fit for analysis Sample condition : 12/01/2023 - 16/01/2023 Sample container: Polythene bottle Period of Analysis Microbiological√ Chemical √ Type of Test

SI	Parameter	Unit	Test method APHA	Results	Acceptable limit IS 10500
No			ATTILL		
	ical Examination	1	2120 B	<1	5
1	Colour	Hazen	2160 A	Agreeable	Agreeable
2	Taste and odor		2510 B	125	50-800
3	Electrical conductivity	μS/cm		BDL	5
4	Turbidity	NTU	2130 B	62	500
5	Total Dissolved solids	mg/L	2540 C	02	
Cha	mical Examination		1500 TI + D	5.93	6.5 - 8.5
_	pH	-	4500 H + B	14	200
7	Total Alkalinity	mg/L	2320 B	2	200
	Total Hardness as CaCO ₃	mg/L	2340 C	2	
8	Calcium Hardness as CaCO ₃	mg/L	3500 Ca B		
9	Magnesium Hardness as CaCO ₃	mg/L	3500 Mg B	BDL	75
10		· mg/L	3500 Ca B	0.80	30
11	Calcium	mg/L	3500 Mg B	BDL	250
12	Magnesium	mg/L	4500 Cl ⁻ B	34.20	200
13	Chloride	mg/L	4500 SO ₄ E	0.02	0.5
14	Sulphate	mg/L	4500 NH ₃ F	BDL	1.5
15	Ammonia	mg/L	3500 Fe B	BDL	1
16	Iron				>*** / 100 1
Bacteriology		cfu/100ml	9222 B	NIL	Nil / 100ml
17	Total Coliform	cfu/100ml	9221 E	NIL	Nil / 100ml
18	Faecal Coliform				

The report is of the sample tested only and shall not be reproduced except in full.

Remarks: pH below the acceptable limit.

Authorized signatory Akhilesh. V. P

Senior Analyst

Amplican Biolabs, KINFRA. Kakkanchery Calicut University Post, Mappikam 673635

AMPLICON BIOLABS

Room No. 17, Park Centre, KINFRA, Kakkanchery, Calicut University P.O, Malappuram 673 635, Kerala 🥯 9745 71 76 89, 9847 55 59 57 😊 ampliconbiolabs@gmail.com 🎯 www.ampliconbiolabs.com

META KARRA



Department Of Health & Family Welfare

SANITARY FITNESS CERTIFICATE

ശുചിത്വ സാക്ഷ്യപത്രം

As per Section (21) of Kerala Public Health Ordinance 2022

O // a alla contre
Peruvallus CHC Taluk/Primary/Family/Community Health Centre
PH:NO e-mail moph (Peruvalloon @ gmail. Com
Ref.NO- Certified that the Building No. 1/86 Of Peruvallocs
Ref.NO- Certified that the building No.
Grama Panchayath/Municipality Proposed for Nava Bhasath Central School
Owned by Manager Navabharath Central School (Senior
Secondary) Paromobil Pecelika P.O. Valakkandy, Pernyallow
has Inspected by me and the sanitary arrangements made at present are satisfactory. Hence a
certificate of sanitary fitness is issued to run the above establishment subject to the conditions
aid down in the Kerala Public Health Ordinance 2022. Any violation of the terms and conditions
of the ordinance will automatically invalid this certificate. This certificate is
valid up to 31/3/20
- Hard

Place: Parambilpeedika

Date: 23/01/2023

Conditions apply.

Health Inspector

Health Inspector Gr. I CHC Peruvalloor arambilpeedika - 676317